

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-22-004880

**Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.**

The French PROCES VERBAL is valid for 5 years starting on January 09th, 2023

Applicant	SIHL GmbH Kreuzauer Straße 33 52355 DÜREN Allemagne
Sample reference	3608 - DURASOL POS BANNER 310
Brief description provided by the applicant	The product, fireproofed in the mass, is composed of a PVC film coated on one side with an ink-receptive acrylic polymer coating with inorganic pigment.
Mass per unit area determined by the laboratory	410 g/m ² ± 10%
Thickness measured by the laboratory	0,30 mm ± 10%
Colour	White
End-use condition	Exhibition wall and display systems

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials

Classification obtained in the official Procès Verbal:

M3

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-22-004880-BE from January 11th, 2023.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenièrès Veyrins-Thuellin, on January 11th, 2023